

**ISOLATION CABIN 12 ACPH (AIR CHANGE PER HOUR) WITH AIR LOCK ROOM (20'X8')**


**LEGEND**

SR. NO.	QUANTITY	ITEMS
D1	01 NOS.	MAIN ENTRANCE DOOR (3'-0" x 6'-6")
D2	01 NOS.	INTERNAL DOOR (2'-3" x 6'-6")
C1	02 NOS.	SHADE ABOVE LOUVERS AND WINDOWS
01	01 NOS.	INLINE FAN WITH BIRD NET & VIRUS BURN OUT (VIRUS BURN OUT OPTIONAL)
02	01 NOS.	3 TR DX CONDENSING UNIT
03	01 NOS.	STARTER PANEL
04	01 NOS.	AHU 350 CFM WITH G4,F8 FILTERS,H14 HEPA FILTER, 3 TR COIL & PLUG TYPE FAN
05	01 NOS.	AIR LOCK CHAMBER WITH INTERLOCKING DOORS

SR. NO.	QUANTITY	ITEMS
06	01 NOS.	DOOR WITH GRILL (750 X 150)
07	02 NOS.	SQ. DIFFUSER (225 X 225)
08	01 NOS.	SS NAHANI TRAP WITH DRAINAGE
09	01 NOS.	BIB TAP WITH ALL PLUMBING
10	01 NOS.	TOILET PAPER HOLDER
11	01 NOS.	EWC WITH ALL PLUMBING, FITTINGS & DRAINAGE
12	01 NOS.	EXTERNAL BULKHEAD LIGHT
13	01 NOS.	WB WITH ALL PLUMBING, FITTINGS & DRAINAGE
14	01 NOS.	SOAP DISH

**NOTES**


**Valisons and Company**  
 68/b, Sarang street, Mumbai 400003  
 Fone : 022 - 23426251, Fax: 022 - 23447854, E-MAIL : info@valisons.com

SCALE 1:5  
 UNLESS OTHERWISE STATED :  
 1. THIRD ANGLE PROJECTION.   
 2. DO NOT SCALE THE DRAWING.  
 3. ALL DIMENSION ARE IN mm.  
 4. GEN. TOLERANCE AS PER IS:2102 (ISO:2768)  
 5. TOLERANCE FOR FABRICATION OF STEEL STRUCTURES AS PER IS:7215.

TITLE  
**ISOLATION CABIN 12 ACPH (AIR CHANGE PER HOUR) WITH AIR LOCK ROOM (20'X8')**

REV.NO.	R E V I S I O N	DATE	DRN.	CH.	APPD.
RO	FOR MANUFACTURE	08.04.2020	Sonal	SHB	ML

DRAWN SPCS      CHECKED SHB      APPROVED ML  
 DATE-RO 08.04.2020      DATE-CURRENT 08.04.2020      DRG.NO. : VC/001/2020      REVISION RO